

SUBJECT: Conditions That Require a Type I Kitchen Hood

EFFECTIVE DATE: September 2002 **REVISED:** July 2004

INTERPRETATION NUMBER: ADM – 3.0509.1

SEE ALSO: 2000 UMC – Section 509.1

INTERPRETATION SUMMARY

This section of the code requires a Type I hood to be provided over commercial grease producing appliances. It is the interpretation of this Department and the Salina Fire Department that "commercial" appliances are those appliances installed in kitchens that are required to be licensed by the Kansas Department of Health and Environment (KDHE). Ranges and cook tops in occupancies such as church or fraternal order kitchens would only need to be protected by a Type II hood if the kitchen does not require a license to operate. Conversely, any type of appliance capable of producing grease laden vapors including, but not limited to, electric skillets, fryers and domestic electric ranges are required to be protected by a Type I hood if the kitchen is licensed by KDHE.